

EXHIBIT 4
Violation of NPDES Permit Discharge Prohibition

Dominion Site	Permit Number	Violation Description
Possum Point Power Station	VA0002071	Unpermitted/Unauthorized discharges from Pond C through point source from at least March 2014 through May 2015
Chesterfield Power Station	VA0004146	On or about July 5, 2017, Defendant experienced an unpermitted discharge of an estimated 277,000 gallons of liquid from the Coal Pile Runoff Pond, which consisted of stormwater overflow comingled with coal fines.
Clover Power Station	VA0083097	Unpermitted discharge of stormwater comingled with coal fines from coal pile/limestone runoff basin, May 19, 2018.
Bath County Power station	VA0053317	Unpermitted discharge of an estimated 3 gallons of hydraulic oil on August 15, 2016.
Chesterfield Power Station	VA0004146	Unpermitted discharge of approximately 5 gallons of hydraulic fluid on January 5, 2018.
Chesterfield Power Station	VA0004146	Unpermitted discharge of turbine lube oil as observed on October 25, 26 and November 1, 2017.
Chesterfield Power Station	VA0004146	Unpermitted discharge of stormwater comingled with coal fines from Coal Pile Runoff Pond, September 28 and 29, 2016.
Chesterfield Power Station	VA0004146 VWP10-1787	Unauthorized discharges of sediment from construction activities during August 2017.